

## Product Specification

## Opteon™ XP40 (R449A)

ASHRAE Number: R449A

## Composition:

Component name	CAS Number	Composition (%w/w)
Tetrafluoroprop-1-ene (HFO1234yf)	754-12-1	24.3 - 25.5
Tetrafluoroethane (R134a)	811-97-2	25.5 - 26.7
Difluoromethane (R32)	75-10-5	23.3 - 24.5
Pentafluoroethane (R125)	354-33-6	24.5 - 25.7

Guaranteed Specifications

UNCONTROLLED

Purity	Minimum	99.5	%w/w
Water content	Maximum	10.0	ppm w/w
Non-Condensable Gas (vapour phase)	Maximum	1.5	% v/v
High boiling residue	Maximum	0.01	% w/w
Acidity (as HCl)	Maximum	1.0	ppm w/w
Chloride	No visible turbidity to pass		
Particulates/Solids	Visually clean to pass		

COPY

Issue No.2

Reviewed April 2020

**Harp International Limited**  
 Gellihirion Industrial Estate, Pontypridd, Rhondda Cynon Taff, CF37 5SX  
 United Kingdom

 Telephone: +44 (0) 1443 842255  
 E-mail: [harp@harpintl.com](mailto:harp@harpintl.com)

 Fax: +44 (0) 1443 841805  
 Web: <http://www.harpintl.com>